

O/o Civil Surgeon , Hisar

Mail-Id:- dhs.cshsr@hry.nic.in

Letter No. HSR/HI/2026/570


Dated: 15-10-2026

OFFICE OF CIVIL SURGEON HISAR

Hygienic and Sanitation certificate

Certified that the condition of the building of **Holy Angel**
School, Tosham road, Hisar with regards to the Sanitation and
Hygienic condition is satisfactory for the one year w.e.f date of
issuing.

Neetu
Principal
Holy Angel School
Tosham Road, Hisar


Dy. Civil Surgeon (Health)
For Civil Surgeon, Hisar



Memo No:- 2133

Date:- 08/10/2026

Subject : Physical / Chemical Examination Report of Water Sample

TC-11875

HC-635

Sample ID/Classification :	HSR/04348/10/2026 / Private	Sample Details	Date & Time
Sender :	HOLY ANGEL SCHOOL, DABRA ROAD, HISAR	Collected By	NARENDER KUMAR
Location :	, HOLY ANGEL SCHOOL, DABRA ROAD, HISAR	Collection Date	07/10/2026 at 14:05
Sample Description :	Drinking Water	Received at lab	07/10/2026 at 17:23
Latitude / Longitude :	75.751805 / 29.100577	Analysis Start Date	07/10/2026
		Analysis End Date	08/10/2026
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	1.12	1 NTU	5 NTU	APHA 24th Edition -2130 B : 2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B : 2023
5	Total Dissolved Solids @ 180°C ± 2°C	223	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C : 2023
6	Total Hardness as CaCO ₃	112	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C : 2023
7	Calcium (as Ca)	20.36	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B : 2023
8	Magnesium (as Mg)	14.87	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B : 2023
9	Total Alkalinity	52	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B : 2023
10	Chloride (as Cl)	90.75	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B : 2023
11	Sulphate as So ₄	47	200 mg/lit.	400 mg/lit.	APHA 24th -4500 SO ₄ -E : 2023
12	Fluoride (as F)	0.218	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C : 2023
13	Iron (as Fe)	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA 45(126-43459) : 2018
14	Nitrate (as NO ₃)	0.8	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D : 2023
15	pH @ 25°C	7.19	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B : 2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

KANCHAN BISHNOI, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in

Krishna Samal
Manager
Holy Angel School
HISAR

Neeto
Principal
Holy Angel School
Tosham Road, Hisar